



**RECOMMENDED CHARACTERISTICS OF THE POWER SUPPLY LINE:**

Main electric board:

- Minimum required power: 15kW - 380V 3-phase + neutral
- Magnetothermal switch and differential: 25A

Line from the main electric board to the control unit board:

- Section of the flexible cable 3-phase + neutral + ground: 5x4mm<sup>2</sup>
- Leave minimum 2m of cable out of the cables well A to connect the equipment

**NOTE:** The motor supply cables and the signal cable must be of maximum 10m length

TRIM ACCURATELY		NOT DIMENSIONED CHAMFERS SM 1x45° NOT DIMENSIONED CONNECTORS R=1	
MATERIAL		TREATMENT	
RAW MATERIAL		FINISHING	
FORMAT A2 ISO 5457		GENERAL TOLERANCES: UNI EN 22768-1 mk	
MACHINE		SHEET 1	
GROUP		DRAWING NUMBER 250007040	
		I.A. 00	

**Dimension in cm**